

2 NYS Route 164 Suite 2 Patterson, NY 12563 Tel: 845-319-6349

Fax: 845-319-6391


## EAST OF HUDSON WATERSHED CORPORATION ADDENDUM #1

## STORMWATER RETROFIT PROJECT Pat-EB-603

The East of Hudson Watershed Corporation (EOHWC) must receive a signed copy of this addendum with the Bid to be considered responsible and complete.

This addendum is issued in response to questions raised at the Mandatory Pre-Bid Conference at the project site on December 4, 2019 and submitted by email thereafter:

- 1. The substantial project completion will be required by May 1, 2020
- 2. This is not a tax exempt project and all appropriate taxes should be included within the contractor's bid. The project is prevailing wage.
- 3. There are no existing grades on the plan. Is the site balanced so that fill will not need to be brought in to repair the washout on the lower section?
  - a) The existing grades are shown on the Conceptual Site Plan Sheet 1 of 3. No grading will be done outside of the construction limits. The slopes on the sides of the channel shall be graded as needed to install the V-Max and Rip-rap (see detail Channel Section on "Channel Restoration Plan & Details" sheet 3 of 3). No fill is required, the project will only entail stabilizing the channel.
- 4. Does any fill need to be exported?
  - a) All excavated material shall be removed from site.
- 5. There is no spacing for the check dams. The drawing states that spacing varies depending on the slope. How should this be addressed?
  - a) Check dams are required for every vertical drop of 2 feet per the detail on Sheet 3 of 3. Base number of check dams off of the "Conceptual Site Plan sheet 1 of 3, where 1 ft. contours are shown
- 6. Is the whole channel lined with rip-rap?
  - a) Yes, the entire channel is lined with rip rap



2 NYS Route 164 Suite 2 Patterson, NY 12563 Tel: 845-319-6349

Fax: 845-319-6391

## **ADDENDUM NO. 1**

## **Receipt Acknowledged**

Bidders must acknowledge receipt of this addendum by stapling this page to the back of the Bid Sheet.

Email a pdf. copy of this receipt to <a href="mailto:info@eohwc.org">info@eohwc.org</a>

**End of Addendum No. 1**